



VISAKHAPATNAM PORT TRUST
M & E DEPT

No.IM&EE/MOF/Elec/F.1124
Dt.23.12.2014.

Sealed tenders are invited for the work of "Repairing, Rewinding and Reconditioning of 50 KVA D.G set Alternator of AOB". The schedule of work is furnished below:

Last date & time of Receipt of Tenders in C.M.E's office:13.01.2015 at 15.00 Hrs.

WORK SCHEDULE

Sl. No	Description	Qty	Unit	Rate Rs.	Amount Rs.
01	Rewinding and reconditioning of Main Stator of 50 KVA 415 V AC 3 Phase Kirloskar make Alternator with super enamel copper wire of existing size and F class insulation material duly removing the old unserviceable winding wire including thorough cleaning, good quality varnishing, baking etc. as required / directed by the Engineer-In-Charge.	01	Job		
02	Rewinding and reconditioning of Exciter wiring of above 50 KVA Alternator with super enamel copper wire of existing size and F class insulation material duly removing the old unserviceable winding wire including thorough cleaning, good quality varnishing, baking etc as required / directed by the Engineer-In-Charge.	01	Job		
03	Reconditioning of 50 KVA Main Rotor (Field) servicing, cleaning, good quality varnishing, baking etc. in order to provide higher megger values as directed by the Engineer-In-Charge	01	Job		
04	Reconditioning of 50 KVA Exciter Rotor, servicing, cleaning, good quality varnishing, baking etc in order to provide higher megger values as directed by the Engineer-In-Charge	01	Job		
05	Dismantling of the above 50 KVA Alternator by removing the end covers, removing the Rotor, Exciter etc and assembling the entire alternator after completion of rewinding / reconditioning works including replacement of defective bearings, to & fro transportation from VPT to Firm's workshop and commissioning of the Alternator as required / directed by the Engineer-In-Charge.	01	Job		
				Total - - - - Rs.	

cont. pg. 2.

: 2 :

Note:

The Estimate cost is Rs.47,000/-

Criteria:

1. The firm has to pay cost of Tender Documents Rs.100/- in the form of B C / P O / D.D of any Nationalised Banks drawn in favour of F.A & C.A.O.

(The firms who are not complying of the above criteria, their tender will be summarily rejected)

Terms and conditions:

1. Firms who are willing to participate in the tender, should have the previous experience in execution of Rewinding & reconditioning work of Motors / Alternators and Firm should submit the notarised copies of proof of the same along with their tender.
2. The Contractor has to submit the offer duly super-scribing the name of the work on the envelope.
3. Firm's quoted rate shall be inclusive of all taxes & duties except Service Tax.
4. Service Tax will be paid extra on submission of documentary evidence.
5. Validity of offer should be 02 months from the last date of receipt of the offers.
6. Statutory deductions will be made from the bills.
7. Conditional offers will be rejected.
8. In case of any clarification, Please contact at phone No. 2873207.
9. a) The workmanship and materials used in this work shall be guaranteed for a period of 06 months from the date of completion of the work.
b) Old winding materials can be retained by the Firm.
c) Bearings, if required will be issued by VPT at free of cost for fixing.
10. The work should be completed within 10 days from the date of lifting the material / site clearance. The time for completion of the work is the essence of the contract.
11. The work shall be completed within the stipulated period, failing which a penalty @ ½% will be levied for every week of delay, on the part of the contractor subject to maximum 10% on total contract / executed value.
12. Tenderers can visit VPT Website www.vizagport.com to download tender documents.

Sealed Quotations are to be addressed to:

Supdt. Engineer (Elec)
Mech & Electrical Engg.Dept.
Visakhapatnam Port Trust,
VISA KHAPATNAM-530035.

CONTRACTOR

Supdt. Engineer (Elec)