

VISAKHAPATNAM PORT TRUST  
MARINE DEPARTMENT

NO. IMAR/FSS/ 44/ 566 /2018

To

Dt. 18/08/2018

- 1) **Fire Safety devices Pvt. Ltd.**  
B-4, Rama Commercial Complex,  
II nd Floor, Near Ajrona, Sector 20-B,  
FARIDABAD- 121 007.  
FAX- 0129-5288700.  
e-mail: info@fcfsd.com
- 2) **Integrated Fire Protection Pvt. Ltd.**  
60A., Pandit Madan Mohan Malabya Sarani,  
(Chakraberia Road, North),  
KOLKATA 700 020  
FAX- (91) (33) 2476 1107, 2283 13 31  
e-mail: info@integratedfire.net
- 3) **K. V. Fire Chemicals (I) Pvt. Ltd.**  
Kamala Niwas, 2<sup>nd</sup> Floor,  
Plot-32, Lane- D, Sector -8, Vashi,  
NAVI MUMBAI- 400 703.  
FAX- 7824712  
e-mail: info@kvfire.com
- 4) **AGNI EQUIPMENT**  
Door. No.28-9-77, 1<sup>st</sup> Floor,  
Surybagh Main Road,  
VISHAKHAPATNAM- 530 020  
Fax 0891 -2526128  
e-mail:  
agniequipment1990@yahoo.com
- 5) **FOAMTECH ANTIFIRE  
COMPANY,**  
57, SHARDA NIKETHAN,  
PITAMPURA,  
NEW DELHI - 110034.  
Ph: +91-11-27016897, 27030306  
e-mail: foamtechantifire@yahoo.com  
sales@foamtechantifire.com

Sir,

Sub: Request for Budgetary Offers for procurement of AFFF 3% Concentrate -Reg  
\*\*\*

Kindly arrange to send Budgetary offers for procurement of Aqueous Film Forming Foam (AFFF) 3% concentrate approx 30, 000ltrs for the use of VPT Fire Service. The specifications are as follows:


1. Aqueous Film Forming Foam (AFFF) Concentrate 3% induction as per IS- 4989 (Part-2) 1987 or latest with ISI mark. The product should be supplied in 200/210 LT HDPE barrels confirming to IS-959. The container shall be marked with Brand Name, Date of manufacturing, Date of expiry and other details.
2. The Manufacturer's test certificate shall be submitted along with supply of Foam Compound.
3. Material should be guaranteed for 24 months from the date of supply or from the date commissioning which ever is earlier. The guarantee certificate shall accompany the supply.
4. The firm has to submit Quality Assurance Plan.
5. The foam manufacturer should have test facilities as IS requirement to carry out quality control tests of the foam produced in his premises.
6. The Toxicity and Bio-degradability of the foam compound should be tested from any NABL accredited Laboratory and the Certificate to that effect to be submitted along with the supply.
7. The supplier has to give Undertaking that the supplied AFFF 3% concentrate compound shall have a shelf life of minimum 10years.

Last Date for Budgetary offer is . 31-Aug-2018

Yours sincerely,

Budgetary offer should sent in Sealed cover.

Address to Fire officer, VPT

  
DY. CONSERVATOR