

No.Gr-II/R-202/18-19/  
Dt. .1.2019

## **CORRIGENDUM**

To  
M/s.

Dear Sir,

Sub:- Procurement of LED flood light & street light luminaire -Reg.  
Ref:-1)This office Enquiry No. Gr-II/R-202/18-19 dt.27-12-2018

\*\*\*\*\*

The subject description and the due date mentioned in the tender enquiry is hereby ammended to read as given below:

<b>S.no</b>	<b>Description as per enquiry</b>	<b>Amended To be Read as</b>
01	LED flood light luminaire of 120 watts made of pressure diecast aluminium housing with powder coated, having toughened glass cover input voltage range of 100 to 270 volts AC power factor, >0.90, high power LED's having efficiacy 120 lumines/watt and junction temperature<85 degree centigrade of IP 65 protection with optics, total harmonic distortion less than 15% at 110 volts AC driver efficiency >90% etc, complete make:any reputed make.	LED street light luminaire 90 watt made of pressure die cast aluminium housing with powder coated having toughened glass cover input voltage range of 100 to 270 volts AC power factor>0.90, high power LED's having efficacy 120 lumines/watt and junction temperature< 85 degree centigrade of IP 65 protection with optics, total harmonic distortion less than 15% at 110 volts AC, driver efficiency>90% etc, complete. Make: any reputed make .
02	22.01.2019	22.2.2019

All the other terms and conditions remain unaltered.

Yours faithfully,

Dy MATERIALS MANAGER

