

VISAKHAPATNAM PORT TRUST
MECHANICAL & ELECTRICAL ENGINEERING DEPARTMENT
M M DIVISION

IM&EE/MMD/GR-2/R-120/1920
Dt. 14-11-2019

AMENDMENT

Dear Sir,

Sub: Procurement of HT Cable Joints -Reg.
Ref: Tender No IM&EE/MMD/GR-2/R-120/1920 Dt 28.10.2019, Due on
20.12.2019

With reference to the above, the make / Brand in the description of the material are hereby Amended and may be read as stated below:

SI NO	DESCRIPTION AS PER ENQUIRY	AMENDMENT TO BE READ AS
1	11KV (E) 3 core X 35 Sq mm., heat Shrinkable Straight through joint XLPE, Aluminium Cable. As per IS 13673/IES 60602 amended uptodate Make Powerseal / Cabseal/ 3M/ Raycham	11KV (E) 3 core X 35 Sq mm., heat Shrinkable Straight through joint XLPE, Aluminium Cable. As per IS 13673/IES 60602 amended uptodate Make Powerseal / Cabseal / 3M/ Raycham / Denson / M Seal / Jointmask / RPG etc.,
2	11KV (E) 3 core X 50 Sq mm., heat Shrinkable Straight through joint XLPE, Aluminium Cable. As per IS 13673/IES 60602 amended uptodate Make Powerseal / Cabseal/ 3M/ Raycham	11KV (E) 3 core X 50 Sq mm., heat Shrinkable Straight through joint XLPE, Aluminium Cable. As per IS 13673/IES 60602 amended uptodate Make Powerseal / Cabseal / 3M/ Raycham / Denson / M Seal / Jointmask / RPG etc.,
3	11KV (E) 3 core X 35 Sq mm., heat Shrinkable outdoor end termination joint kit XLPE, Aluminium Cable. As per IS 13673/IES 60602 amended uptodate Make Powerseal / Cabseal/ 3M/ Raycham	11KV (E) 3 core X 35 Sq mm., heat Shrinkable outdoor end termination joint kit XLPE, Aluminium Cable. As per IS 13673/IES 60602 amended uptodate Make Powerseal / Cabseal / 3M/ Raycham / Denson / M Seal / Jointmask / RPG etc.,

All the other terms and conditions of the purchase order remains unaltered

Yours faithfully,


14/11/19
Dy.MATERIALS MANAGER

Copy to: CME for information please
Copy to: A.E(E/M) for information please.